

○SHEET KEYNOTES

- REMOVE EXISTING PLUMBING FIXTURES AND ASSOCIATED PLUMBING BACK TO ACTIVE MAINS AND CAP.
- REMOVE EXISTING UNIT HEATER AND ASSOCIATED GAS PIPING BACK TO ACTIVE MAINS AND CAP. FIELD VERIFY EXACT LOCATION.
- 3. RELOCATE EXISTING UNIT HEATER TO FURNITURE STORAGE SPACE. EXTEND GAS PIPING AS REQUIRED. COORDINATE EXACT LOCATION WITH ARCHITECT AND OWNER.
- 4. RUN EXHAUST DUCT UP THROUGH ROOF AND TERMINATE WITH WEATHER CAP. MAINTAIN 10 FEET OF CLEARANCE FROM AIR INTAKES FIELD VERIFY EXACT LOCATION.
- 5. PROVIDE NEW PROGRAMMABLE THERMOSTAT AND RUN AND CONNECT TO ROOFTOP UNIT AS SHOWN. COORDINATE EXACT PLACEMENT OF THERMOSTAT WITH ARCHITECT. FIELD VERIFY EXACT LOCATION.
- 6. LEAVE FULL SIZE RETURN AIR OPENING AT EXISTING ROOFTOP UNIT RETURN AIR OUTLET. FIELD VERIFY EXACT LOCATION.
- 7. PROVIDE 4" VENT THROUGH ROOF FOR WATER HEATER. TERMINATE ABOVE ROOF WITH WEATHER CAP.
- 8. PROVIDE 4" COMBUSTION AIR DUCT AND TERMINATE AT ROOF WITH WEATHER CAP. TERMINATE OTHER END 12" BELOW CEILING.

SYMMETRY FIRST

ARCHITECTS,

8600 Foundry Street
Box 2069
Savage, MD 20763
240-568-0700
240-568-0354 fax
www.symmetryfirst.com

STAMP

PROFESSIONAL CERTIFICATION: I HEREBY CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF MARYLAND.

LICENSE NO. 38508

EXPIRATION DATE: MARCH 03, 2012

NOTE: THESE DRAWINGS ARE THE PROPERTY OF SYMMETRY FIRST ARCHITECTS, LLC AND, AS SUCH, MAY NOT BE REPRODUCED OR RE-USED, EITHER WHOLLY OR IN PART, WITHOUT PRIOR WRITTEN CONSENT OF SYMMETRY FIRST ARCHITECTS, LLC.

PROJECT PHASE

DOCUMENTS

PROJECT TITLE

A.O.C. TENANT BUILD-OUT

2001COMMERCE PARK DR., SUITE 2001-B ANNAPOLIS, MD 21401

REVISIONS		
SYMBOL	DATE	ISSUED FOR
\bigcap	10.21.11	PERMIT REVISION

PROJECT NUMBER 11-160
DATE 9.1.11

SCALE AS NOTED

MECHANICAL PLANS

SHEET NUMBER

M.101

MECHANICAL FLOOR PLAN

SCALE: 1/8" = 1'-0"